



**ADDENDUM NO 1**

**ADDENDUM NO 1**

**FLORIDA MUNICIPAL POWER AGENCY**

**INVITATION TO BID NO. 2019-001**  
**July 3, 2019**

FMPA Invitation to Bid Number 2019-001, Purchase and Delivery of Three Phase Padmount Transformers Bid, has changed to reflect the following additions, deletions, and/or modifications:

**Item No. 1**

Modification to the Bid Document:

City of Lake Worth Beach has been added as a listed Participating Member on this bid. Page TC-1 has been modified to reflect this change.

**Item No. 2**

Addition to the Technical Specifications:

Section 11.16 has been added to the Technical Specifications - Optional Accessories. The paragraph is as follows:

11.16 Each transformer shall be equipped with a non-resettable device which detects and provides external indication of internal transformer faults, and also incorporates pressure relief functionality. The approved device is manufactured by IFD Corporation or approved equal.

**Item No. 3**

Addition to the bid line items:

26,400/4,160Y primary voltage items has been added to the bid for the City of Lake Worth Beach. The change has been made on AURSI.

**Item No. 4**

Modifications to the bid schedule:

The bid opening date has been extended to **August 1, 2019** at 1:30pm.

All other aspects of the bid document remain the same.

\* \* \* \* \*