

**Treasure Coast Energy Center (TCEC) HRSG Penetration Seals**  
**FMPA RFP# 2026-206**  
**Questions & Answers**

**1Q:** Will you please confirm that clamshell Bellows are the only acceptable solution for all pen seals locations? Also, will you please confirm that all work will be completed in not more than 15 shifts?

**1A:** Bidders are free to offer alternatives. However, clamshell bellows style is considered the base specification. Bidders must bid toward the base for alternatives to be considered. Work must be completed in no more than 15 shifts per dates provided in section 7 of scope of work.