

MEC 40-Ton A/C Unit Replacement
FMPA RFP# 2026-213
Questions & Answers - Revision 1

1Q: Can you tell me if it's a gas system or a heatpump system?

1A: It is just a cooling system, no heating. (heat pump, heat strips, etc) No heating will be required.

2Q: Duct work repairs

2A: Make sure seams outside the building are tight and repair return section that has been patched and dented.

3Q: Crane company requirements

3A: Must be a reputable company with insurance. FMPA has the right to review and deny if insurance and safety is not adequate.

4Q: Can the crane close down the access road in front of the AC during the lift?

4A: Yes

5Q: Do you need a service for changing the air filters?

5A: No, that is already taken care of.