

SI CT2 & CT3 GSU Transformer Bushing Replacement
FMPA RFP# 2026-214
Questions & Answers

1Q: Clarification on what additional vacuum processing and moisture reduction services they are referring to under "Alternate No. 3" on page 23.

1A: Alternate No. 3 is intended to provide pricing for additional oil processing, vacuum treatment, and moisture reduction services that may be required following completion of the bushing replacement work. While the extent of any additional processing cannot be determined in advance, FMPA would like to understand the potential cost and schedule impacts should further treatment be necessary to achieve acceptable transformer oil and insulation system conditions.